



C No. -4525

INDIAN TESTING CENTRE (P) LTD.

101, SASHCO BHAWAN, NEAR AAKASH CINEMA, AZADPUR COMMERCIAL COMPLEX
AZADPUR, DELHI-110033 (INDIA). TELEFAX : 91-11-27671535, 27671542, 24505822
visit us at www.indiantestingcentre.org E-mail : info@indiantestingcentre.org



T-1698/T-1699

CQR/004(00/01)

ISSUED TO:- The Principal,
DAV Centenary Public School,
Sector B-4, Pocket - 5, DDA Project,
Narela, Delhi - 110040.

TEST CERTIFICATE NO.:- 6202003186001
DATE:- 24 - MARCH - 2020
REFERENCE.NO.- DAVCPS/1108/2019-20
DATE OF RECEIPT:- 18 - MARCH - 2020
PAGE:- 1 OF 1

SAMPLE DESCRIPTION :- Drinking Water.

TEST CERTIFICATE

S.NO.	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS : 10500 - 2012)	
				ACCEPTABLE LIMIT	PERMISSIBLE LIMIT IN ABSENCE OF ALTERNATE SOURCE
1.	Colour, Hazen Unit	IS:3025 (Pt.-4)	< 1	5.00 Max	15.00 Max.
2.	Odour	IS:3025(Pt.-5)	agreeable	Agreeable	Agreeable
3.	Turbidity, NTU	IS:3025(Pt.-10)	< 1	1.00 Max.	5.00 Max.
4.	Ph Value	IS:3025(Pt.-11)	7.54	6.50 - 8.50	No Relaxation
5.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Pt.-21)	52.90	200.00 Max.	600.00 Max.
6.	Iron as Fe, mg/l	IS:3025(Pt.-53)	0.10	0.30 Max.	No Relaxation
7.	Chloride as Cl, mg/l	IS:3025(Pt.-32)	41.50	250.00 Max.	1000.00 Max.
8.	Total Dissolved Solids, mg/l	IS:3025(Pt.-16)	93.00	500.00 Max.	2000.00 Max.
9.	Calcium as Ca, mg/l	IS:3025(Pt.-40)	10.70	75.00 Max.	200.00 Max.
10.	Sulphate as SO ₄ , mg/l	IS:3025(Pt.-24)	14.20	200.00 Max.	400.00 Max.
11.	Total Alkalinity as CaCO ₃ , mg/l	IS:3025(Pt.-23)	27.00	200.00 Max.	600.00 Max.
12.	Magnesium as Mg, mg/l	IS:3025(Pt.-46)	5.15	30.00 Max.	100.00 Max.
13.	Fluoride as F, mg/l	IS:3025(Pt.-60)	< 1	1.00 Max.	1.50 Max.
14.	Nitrate as NO ₃ , mg/l	IS:3025(Pt.-34)	0.50	45.00 Max.	No Relaxation
15.	E. Coli per 100 ml	IS:15185-2016	absent	absent/100 ml	---
16.	Coliform per 100 ml	IS:15185-2016	absent	absent/100 ml	---

REMARKS:- The sample conforms to the acceptable limits of IS : 10500 - 2012 for drinking purpose with respect to above tests.

दिल्ली नगर निगम



MUNICIPAL CORPORATION OF DELHI

Office of the Dy. Health Officer,
Narela Zone

No. DHO/NRZ/2016/ 181


Dated: 30.05.16

School Health Certificate

- | | | |
|-----------------------------|---|-----------------------------------|
| 1. Name of the School | : | DAV Centenary Public School |
| 2. Location | : | Narela Delhi-40 |
| 3. School Timing | : | 8.00 am to 2.10 pm |
| 4. No. of staff | : | 92 (Male-23 Female-69) |
| 5. No. of Students | : | Male- 1424
Female 877
2301 |
| 6. No. of Rooms | : | 71 |
| 7. No. of Fans in each room | : | 4 |
| 8. No. of Urinals/Toilets | : | 56(28 For Male, 28 For Female) |
| 9. Drinking Water | : | Water Test Report Approved by MCD |

During the course of inspection, it is found that the school is functioning in good sanitary and hygienic condition.

Principal,
DAV Centenary Public School,
Narela Delhi-40


Dy. Health Officer
Dr. S.B. SINGH, Narela Zone
Dy. Health Officer,
Narela Zone North DMC