



# INDIAN TESTING CENTRE (P) LTD.

101, SASHCO BHAWAN, NEAR AAKASH CINEMA, AZADPUR COMMERCIAL COMPLEX  
AZADPUR, DELHI-110033 (INDIA). TELEFAX : 91-11-27671535, 27671542, 24505822  
visit us at www.indiantestingcentre.org E-mail : info@indiantestingcentre.org



ISO/IEC 17025  
COR/004(2005)

ISSUED TO:- The Principal,  
DAV Centenary Public School,  
Sector B-4, Pocket - 5, DDA Project,  
Narela, Delhi - 110040

TEST CERTIFICATE NO - 8262506125001  
DATE - 19 - JUNE - 2025  
REFERENCE NO - DAV/CP/1405/2025/26  
DATE OF RECEIPT - 12 - JUNE - 2025  
PAGE - 1 OF 1

SAMPLE DESCRIPTION - One Sample of Drinking Water was Submitted

## TEST CERTIFICATE

S. NO.	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS : 10500 - 2012)	
				ACCEPTABLE LIMIT	PERMISSIBLE LIMIT IN ABSENCE OF ALTERNATE SOURCE
1	Colour, Hazen Unit	IS 3025 (Pt -4)	< 1	5.00 Max	15.00 Max
2	Odcour	IS:3025(Pt -5)	agreeable	Agreeable	Agreeable
3	Turbidity, NTU	IS:3025(Pt-10)	< 1	1.00 Max.	5.00 Max.
4	Ph Value	IS:3025(Pt-11)	7.25	6.50 - 8.50	No Relaxation
5	Total Hardness as CaCO <sub>3</sub> , mg/l	IS:3025(Pt-21)	81.00	200.00 Max	600.00 Max.
6	Iron as Fe, mg/l	IS:3025(Pt-53)	0.10	0.30 Max.	No Relaxation
7	Chloride as Cl, mg/l	IS:3025(Pt-32)	48.50	250.00 Max.	1000.00 Max.
8	Total Dissolved Solids, mg/l	IS:3025(Pt-18)	151.00	500.00 Max.	2000.00 Max.
9	Calcium as Ca, mg/l	IS:3025(Pt-40)	9.50	75.00 Max.	200.00 Max.
10	Sulphate as SO <sub>4</sub> , mg/l	IS:3025(Pt-24)	32.00	200.00 Max.	400.00 Max.
11	Total Alkalinity as CaCO <sub>3</sub> , mg/l	IS:3025(Pt-23)	27.00	200.00 Max.	600.00 Max.
12	Magnesium as Mg, mg/l	IS 3025(Pt-45)	5.90	30.00 Max.	100.00 Max.
13	Fluoride as F, mg/l	IS 3025(Pt-60)	< 1	1.00 Max.	1.50 Max.
14	Nitrate as NO <sub>3</sub> , mg/l	IS:3025(Pt-34)	1.00	45.00 Max.	No Relaxation
15	E. Coli per 100 ml	IS:15185-2016	absent	absent/100 ml	---
16	Coliform per 100 ml	IS 15185-2016	absent	absent/100 ml	---

REMARKS:- The sample conforms to the acceptable limits of IS : 10500 - 2012 for drinking purpose with respect to above tests

*Anupam*  
Principal

DAV Centenary Public School  
Sector B-4, Pocket-5  
DDA Project, Narela, Delhi-110040



AUTHORIZED SIGNATORY

INDIAN TESTING CENTRE (P) LTD. ISO 9001 CERTIFIED AND ISO CERTIFIED ORGANIZATION

Subject to Terms & Conditions Overleaf