



INDIAN TESTING CENTRE (P) LTD.

101, SASHCO BHAWAN, NEAR AAKASH CINEMA, AZADPUR COMMERCIAL COMPLEX
AZADPUR, DELHI-110033 (INDIA). TELEFAX : 91-11-27671535, 27671542, 24505822
visit us at www.indiantestingcentre.org E-mail : info@indiantestingcentre.org



C No. -4525

CQR/004(00/01)

AN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE

SUED TO:- The Principal,
DAV Centenary Public School,
Sector B-4, Pocket - 5, DDA Project,
Narela, Delhi - 110040.

TEST CERTIFICATE NO.: - 6202606186001

DATE:- 26 - JUNE - 2026

REFERENCE NO.- DAVCPS/438/2026-27

DATE OF RECEIPT:- 18 - JUNE - 2026

PAGE:- 1 OF 1

SAMPLE DESCRIPTION :- One Sample of Drinking Water was Submitted.

DIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE

TEST CERTIFICATE

S.NO.	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS : 10500 - 2012)	
				ACCEPTABLE LIMIT	PERMISSIBLE LIMIT IN ABSENCE OF ALTERNATE SOURCE
1.	Colour, Hazen Unit	IS:3025 (Pt.-4)	< 1	5.00 Max	15.00 Max.
	Odour	IS:3025(Pt.-5)	agreeable	Agreeable	Agreeable
3.	Turbidity, NTU	IS:3025(Pt.-10)	< 1	1.00 Max.	5.00 Max.
4.	Ph Value	IS:3025(Pt.-11)	7.19	6.50 - 8.50	No Relaxation
5.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Pt.-21)	87.00	200.00 Max.	600.00 Max.
6.	Iron as Fe, mg/l	IS:3025(Pt.-53)	0.10	0.30 Max.	No Relaxation
7.	Chloride as Cl, mg/l	IS:3025(Pt.-32)	57.00	250.00 Max.	1000.00 Max.
8.	Total Dissolved Solids, mg/l	IS:3025(Pt.-16)	168.00	500.00 Max.	2000.00 Max
9.	Calcium as Ca, mg/l	IS:3025(Pt.-40)	9.20	75.00 Max.	200.00 Max.
10.	Sulphate as SO ₄ , mg/l	IS:3025(Pt.-24)	30.00	200.00 Max.	400.00 Max.
11.	Total Alkalinity as CaCO ₃ , mg/l	IS:3025(Pt.-23)	27.00	200.00 Max.	600.00 Max.
12.	Magnesium as Mg, mg/l	IS:3025(Pt.-46)	5.00	30.00 Max.	100.00 Max.
13.	Fluoride as F, mg/l	IS:3025(Pt.-60)	< 1	1.00 Max.	1.50 Max.
14.	Nitrate as NO ₃ , mg/l	IS:3025(Pt.-34)	1.70	45.00 Max.	No Relaxation
15.	E. Coli per 100 ml	IS:15185-2016	absent	absent/100 ml	---
16.	Coliform per 100 ml	IS:15185-2016	absent	absent/100 ml	---

REMARKS:- The sample conforms to the acceptable limits of IS : 10500 - 2012 for drinking purpose with respect to above tests.

Principal
Principal

D.A.V. Centenary Public School
Sector B-4, Pocket - 5, DDA Project,
Narela, Delhi-110040



AUTHORISED SIGNATORY

INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE INDIAN TESTING CENTRE

AN NABL ACCREDITED (T-1698/T-1699) AND ISO CERTIFIED ORGANIZATION

Subject to Terms & Conditions Overleaf