



INDIAN TESTING CENTRE (P) LTD.

101, SASHCO BHAWAN, NEAR AAKASH CINEMA, AZADPUR COMMERCIAL COMPLEX
AZADPUR, DELHI-110033 (INDIA). TELEFAX : 91-11-27671535, 27671542, 24505822
visit us at www.indiantestingcentre.org E-mail : info@indiantestingcentre.org



C No. -4525

CQR/004(00/01)

SUED TO:- The Principal,
DAV Centenary Public School,
Sector B-4, Pocket - 5, DDA Project,
Narela, Delhi - 110040.

TEST CERTIFICATE NO.: - 6202606186001

DATE:- 26 - JUNE - 2026

REFERENCE.NO.- DAVCPS/438/2026-27

DATE OF RECEIPT:- 18 - JUNE - 2026

PAGE:- 1 OF 1

SAMPLE DESCRIPTION :- One Sample of Drinking Water was Submitted.

TEST CERTIFICATE

S.NO.	TESTS	TEST METHODS	RESULTS	REQUIREMENTS (IS : 10500 - 2012)	
				ACCEPTABLE LIMIT	PERMISSIBLE LIMIT IN ABSENCE OF ALTERNATE SOURCE
1.	Colour, Hazen Unit	IS:3025 (Pt.-4)	< 1	5.00 Max.	15.00 Max.
2.	Odour	IS:3025(Pt.-5)	agreeable	Agreeable	Agreeable
3.	Turbidity, NTU	IS:3025(Pt.-10)	< 1	1.00 Max.	5.00 Max.
4.	Ph Value	IS:3025(Pt.-11)	7.19	6.50 - 8.50	No Relaxation
5.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Pt.-21)	87.00	200.00 Max.	600.00 Max.
6.	Iron as Fe, mg/l	IS:3025(Pt.-53)	0.10	0.30 Max.	No Relaxation
7.	Chloride as Cl, mg/l	IS:3025(Pt.-32)	57.00	250.00 Max.	1000.00 Max.
8.	Total Dissolved Solids, mg/l	IS:3025(Pt.-16)	168.00	500.00 Max.	2000.00 Max.
9.	Calcium as Ca, mg/l	IS:3025(Pt.-40)	9.20	75.00 Max.	200.00 Max.
10.	Sulphate as SO ₄ , mg/l	IS:3025(Pt.-24)	30.00	200.00 Max.	400.00 Max.
11.	Total Alkalinity as CaCO ₃ , mg/l	IS:3025(Pt.-23)	27.00	200.00 Max.	600.00 Max.
12.	Magnesium as Mg, mg/l	IS:3025(Pt.-46)	5.00	30.00 Max.	100.00 Max.
13.	Fluoride as F, mg/l	IS:3025(Pt.-60)	< 1	1.00 Max.	1.50 Max.
14.	Nitrate as NO ₃ , mg/l	IS:3025(Pt.-34)	1.70	45.00 Max.	No Relaxation
15.	E. Coli per 100 ml	IS:15185-2016	absent	absent/100 ml	---
16.	Coliform per 100 ml	IS:15185-2016	absent	absent/100 ml	---

REMARKS:- The sample conforms to the acceptable limits of IS : 10500 - 2012 for drinking purpose with respect to above tests.



AUTHORISED SIGNATORY

AN NABL ACCREDITED (T-1698/T-1699) AND ISO CERTIFIED ORGANIZATION

Subject to Terms & Conditions Overleaf



Scanned with OKEN Scanner